GSTIN: 05BINPS3051B1ZH

Mob. 9634606211

INAGAR GARHWAL, UTTARAKHAND IV CAMERA AND GENERAL ORDER SUPPLIER V. C. S. GARHWALI MARG, SRINAGAR

Ref. no......

Date 27 2

HYDRO PRESSURE TEST CERTIFICATE

This is to certify that the following fire extinguishers we have received from Neel Kanth Homestay, Chopfa., we have tested them as per the test results whose details are as follows:

test results whose details are as follows:			
S.No.	Type of Extinguisher	Pressure Tested	Duration Quantity
1.	ABC 4 kg	35 kg/cm^2	2.5 min — 0
2.	ABC 6 kg	35 kg/cm^2	2.5 min
3.	ABC 9 kg	35 kg/cm ²	2.5 min
4.	CO ₂ 4.5 kg	250 kg/cm ²	2.5 min
5.	AFFF 9 Lt	35 kg/cm ²	2.5 min
			Total 01

Scanned with